

## NOTES:

- 1. TYPICAL SIDEWALK SHALL BE 4" THICK. SIDEWALK THROUGH DRIVEWAYS SHALL BE 5" THICK, OR THE DRIVEWAY THICKNESS, WHICHEVER IS GREATER. SIDEWALKS THROUGH ALLEYS SHALL BE 7" THICK.
- 2. 1/2" EXPANSION MATERIAL REQUIRED AT PROPERTY LINE AND DRIVEWAYS AND EACH 75 FT. INCREMENT ALONG LENGTH OF SIDEWALK.
- 3. SIDEWALK CROSSING DRIVEWAY MAY HAVE A MAX. 4% CROSS SLOPE AS APPROVED WHERE GRADE RESTRICTIONS EXIST. NORMAL SIDEWALK CROSS—SLOPE SHALL TRANSITION TO SPECIAL SLOPE WITHIN 16—FOOT LENGTH.
- 4. MINIMUM WIDTH IS 4 FT FOR RESIDENTIAL AND 5 FT FOR COMMERCIAL AREAS.

FILE NO.: 2700-112	CEDAR RAPIDS METROPOLITAN AREA	. (
APPROVAL DATE: APRIL 2003	STANDARD DETAILS FOR PUBLIC IMPROVEMENTS	
REVISION NO.: 1	TYPICAL SIDEWALK	NO.
REVISION DATE: APRIL 2003	THIOAL SIDEWALK	NO.
NEVISION DAIL: AINE 2000	AND RIGHT—OF—WAY GRADING	2700-112